



RC filter must be used when contactor coil voltage 220V AC.
 *MRS-A3: OSG coil activation switch for manual rescue operation.

KSG : EN 60947-4-1 AC3
 Type Contactor

First Drawing	Modification	Board Series	ACT		Client	FRENIC LIFT INVERTER UCM A3 WITH OSG	Page Number	5
Date	03.12.2012	Date	26.12.2012		Project Number	SKY 311 (ACT)	Total Number of Pages 8	
Draw	SKY	Draw	SKY		Form Number	SKY 311 (ACT)		

A03 : LIFT TYPE/ 006
 A17 : UCM CONTROLLER /004